



# Village of Cumberland Drinking Water 2014 Annual Report

Reporting Period:	January 1, 2014 to December 31, 2014
Operating Permit Number:	1414314
Drinking Water System Owner:	Corporation of the Village of Cumberland
Drinking Water System Contact:	
Name:	Kevin Fitzgerald
Phone No:	(250) 336-2291 Cell: 250-792-1593
Email:	publicworks@cumberland.ca

**1. Microbiological testing completed during this reporting period:**

- a) bacteriological results attached to this report.  None detected  
 b) adverse bacteriological results:  Listed in table below:

Adverse Results:

Date	Site #	Total Coliform	E.Coli	Reason	Corrective Action
July 2, 2014	4	580		High turb. and hydrant mtc.	Flushed and resampled
July 2, 2014	2	3		High turb. and hydrant mtc.	Flushed and resampled
Oct. 28, 2014	7	OG	OG	Possible sampling error	Flushed and resampled
Oct. 28, 2014	4	1		High turbidity	Flushed and resampled
Oct. 3, 2014	6	1		High turbidity	Flushed and resampled

**2. Chemical results for this reporting period:**

- a) most recent chemical analysis attached to this report.  
 b) chemical parameters listed in *The Guidelines for Canadian Drinking Water Quality (GCDWQ)* are:  all within the GCDWQ  
 above the GCDWQ and are listed below:

Parameters above the Guidelines:

Parameter	Result	Max. Acceptable Concentration	Aesthetic Objective	Treatment/Corrective Action

**3. Summarize additional testing and sampling carried out in accordance with the requirement of a Water Source approval, Written Order or as per the conditions of your *Operating Permit*.**

- no additional testing
- additional testing listed below:

Additional testing:

Description of parameter & reason for sampling	Health parameter or non-health related parameter	Corrective action necessary (YIN?)	Corrective action taken

**4. Water Quality Complaints:**

During the course of the year, the water system:

- did not receive water quality complaints (ie taste, odour, colour, etc)
- received water quality complaints and are listed below:

**Water Quality Complaints:**

Date	Water Quality Complaint	Corrective action taken

**5. Adverse results: Total number of adverse results during this reporting period for insufficient water supply, malfunction of disinfection equipment or elevated turbidity:**

- No adverse results
- Adverse results listed below:

**Adverse Results**

Incident date	Corrective action	Corrected by

**6. Description of the system:**

Sources of raw water:

- Groundwater
- Surface water
- Other (specify): \_\_\_\_\_

Does the drinking water system have disinfection?  Yes  No Disinfection methods (check boxes that apply):

- Chlorination
- Ultraviolet light
- Ozonation
- Other (specify): \_\_\_\_\_

Does the drinking water system have treatment?  Yes  No treatment type (check boxes that apply):

- Particulate cartridge filters
- Membrane filtration
- Carbon filter
- Sand filtration
- Reverse osmosis
- Other (specify): \_\_\_\_\_

**7. Major expenses incurred during the period covered by the report:**

To purchase or install required equipment:	
To repair equipment:	
To replace equipment:	
To complete annual maintenance of system: (system flushing, replacement of carbon filters, etc)	Replaced Lake Road water main (27,860.79) Maryport 4th-5th (66,820) Allen Ave to 3rd (128,734)
To complete specialist report (specify):	

**8. Further communication with users:**

a) Indicate how you notified system users that your annual report is available, and is free of charge:

- hand delivered
- public access/notice via web
- public access/notice via government office
- public access/notice via newspaper
- public access/notice via bill stuffier
- public access/notice via other method (specify): \_\_\_\_\_

b) Improvements or remedial actions required by the Drinking Water Officer:

- no action required
- drinking Water Officer inspection report attached to report
- actions required by Drinking Water Officer listed below:

Improvements/Remedial Action

Required Action	Completion Date
Emergency response upgrade	2015
Rechlorination + AutoFlush for Disc Centre	Complete

c. Future water system improvements:

- no improvements planned
- improvements listed below:

Future Improvements

Future plans	Planned Completion Date
W.W. station COMBINED WITH new building	2015
including new chlorine disinfection system	2015

d) Emergency Response Plan can be accessed by:

- posting on web
- posting at nearest government office
- contacting water system owner
- Other (specify): \_\_\_\_\_

## VILLAGE OF CUMBERLAND WATER SUPPLY

### Facility Location:

2673 Dunsmuir Avenue  
Cumberland

### Facility Information:

Facility Type: DWT

### Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	10-Feb-2015	L1	L1
Site #7 - 2476 Dunsmuir Avenue	10-Feb-2015	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	2-Feb-2015	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	26-Jan-2015	L1.0	L1.0
Site #7 - 2476 Dunsmuir Avenue	20-Jan-2015	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	19-Jan-2015	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	19-Jan-2015	L1.0	L1.0
Site #2 - 3328 Second Street, 3328 Second Street	19-Jan-2015	C	
Site #2 - 3328 Second Street, 3328 Second Street	19-Jan-2015	L1.0	L1.0
Site #7 - 2476 Dunsmuir Avenue	19-Jan-2015	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	13-Jan-2015	8	L1
Site #2 - 3328 Second Street, 3328 Second Street	13-Jan-2015	6	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	13-Jan-2015	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	13-Jan-2015	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	13-Jan-2015	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	13-Jan-2015	L1	L1
Site #7 - 2476 Dunsmuir Avenue	13-Jan-2015	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	12-Jan-2015	L1.0	L1.0
Site #5 - 3607 Small Road, 3607 Small Road	5-Jan-2015	L1.0	L1.0
Site #4 - 3190 Royston Road, 3190 Royston Road	29-Dec-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	22-Dec-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	15-Dec-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	8-Dec-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	8-Dec-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	8-Dec-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	8-Dec-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	8-Dec-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	8-Dec-2014	L1	L1

Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	8-Dec-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	8-Dec-2014	L1	L1

Show: 30  results per page

**⬆ PREVIOUS ⬇ NEXT**

Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	26-Nov-2013	L1	L1
Site #7 - 2476 Dunsmuir Avenue	26-Nov-2013	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	18-Nov-2013	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	12-Nov-2013	L1.0	L1.0

Show:  results per page

**↑ PREVIOUS ↓ NEXT**

## VILLAGE OF CUMBERLAND WATER SUPPLY

### Facility Location:

2673 Dunsmuir Avenue  
Cumberland

### Facility Information:

Facility Type: DWT

### Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Site #7 - 2476 Dunsmuir Avenue	1-Dec-2014	L1.0	L1.0
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	24-Nov-2014	L1.0	L1.0
Site #5 - 3607 Small Road, 3607 Small Road	17-Nov-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	17-Nov-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	17-Nov-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	17-Nov-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	17-Nov-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	17-Nov-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	17-Nov-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	17-Nov-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	10-Nov-2014	L1.0	L1.0
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	4-Nov-2014	L1.0	L1.0
Site #4 - 3190 Royston Road, 3190 Royston Road	31-Oct-2014	L1.0	L1.0
Site #7 - 2476 Dunsmuir Avenue	31-Oct-2014	L1.0	L1.0
Site #2 - 3328 Second Street, 3328 Second Street	28-Oct-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	28-Oct-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	28-Oct-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	28-Oct-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	28-Oct-2014	1	L1
Site #5 - 3607 Small Road, 3607 Small Road	28-Oct-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	28-Oct-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	28-Oct-2014	OG	OG
Site #1 - 2040 Derwent , 2040 Derwent	20-Oct-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	14-Oct-2014	L1.0	L1.0
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	6-Oct-2014	L1.0	L1.0
Site #5 - 3607 Small Road, 3607 Small Road	30-Sep-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	30-Sep-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	30-Sep-2014	L1	L1



Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	30-Sep-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	30-Sep-2014	L1	L1

Show:  results per page

**↑ PREVIOUS ↓ NEXT**

## VILLAGE OF CUMBERLAND WATER SUPPLY

### Facility Location:

2673 Dunsmuir Avenue  
Cumberland

### Facility Information:

Facility Type: DWT

### Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Site #5 - 3607 Small Road, 3607 Small Road	30-Sep-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	30-Sep-2014	1	L1
Site #7 - 2476 Dunsmuir Avenue	30-Sep-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	22-Sep-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	16-Sep-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	8-Sep-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	2-Sep-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	25-Aug-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	25-Aug-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	25-Aug-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	25-Aug-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	25-Aug-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	25-Aug-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	25-Aug-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	25-Aug-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	20-Aug-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	11-Aug-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	6-Aug-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	28-Jul-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	28-Jul-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	28-Jul-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	28-Jul-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	28-Jul-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	28-Jul-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	28-Jul-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	28-Jul-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	21-Jul-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	14-Jul-2014	L1	L1

Site #2 - 3328 Second Street, 3328 Second Street	14-Jul-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	14-Jul-2014	L1	L1

Show: 30 results per page

**⬆ PREVIOUS** **⬇ NEXT**

## VILLAGE OF CUMBERLAND WATER SUPPLY

### Facility Location:

2673 Dunsmuir Avenue  
Cumberland

### Facility Information:

Facility Type: DWT

### Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Site #7 - 2476 Dunsmuir Avenue	7-Jul-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	2-Jul-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	2-Jul-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	2-Jul-2014	3	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	2-Jul-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	2-Jul-2014	EST 580	L1
Site #5 - 3607 Small Road, 3607 Small Road	2-Jul-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	2-Jul-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	2-Jul-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	23-Jun-2014	L1.0	L1.0
Site #4 - 3190 Royston Road, 3190 Royston Road	16-Jun-2014	L1.0	L1.0
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	9-Jun-2014	L1.0	L1.0
Site #2 - 3328 Second Street, 3328 Second Street	2-Jun-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	26-May-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	26-May-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	26-May-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	26-May-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	26-May-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	26-May-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	26-May-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	26-May-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	20-May-2014	L1.0	L1.0
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	12-May-2014	L1.0	L1.0
Site #5 - 3607 Small Road, 3607 Small Road	5-May-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	5-May-2014	L1.0	L1.0
Site #4 - 3190 Royston Road, 3190 Royston Road	28-Apr-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	28-Apr-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	28-Apr-2014	L1	L1

Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	28-Apr-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	28-Apr-2014	L1	L1

Show:  results per page

**↑ PREVIOUS** **↓ NEXT**

## VILLAGE OF CUMBERLAND WATER SUPPLY

### Facility Location:

2673 Dunsmuir Avenue  
Cumberland

### Facility Information:

Facility Type: DWT

### Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Site #5 - 3607 Small Road, 3607 Small Road	28-Apr-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	28-Apr-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	28-Apr-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	22-Apr-2014	L1.0	L1.0
Site #2 - 3328 Second Street, 3328 Second Street	14-Apr-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	7-Apr-2014	L1.0	L1.0
Site #7 - 2476 Dunsmuir Avenue	31-Mar-2014	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	31-Mar-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	31-Mar-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	31-Mar-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	31-Mar-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	31-Mar-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	31-Mar-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	31-Mar-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	25-Mar-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	17-Mar-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	11-Mar-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	4-Mar-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	25-Feb-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	25-Feb-2014	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	25-Feb-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	25-Feb-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	25-Feb-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	25-Feb-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	25-Feb-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	25-Feb-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	17-Feb-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	11-Feb-2014	L1	L1

Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	3-Feb-2014	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	27-Jan-2014	L1	L1

Show: 30  results per page

**⬆ PREVIOUS ⬇ NEXT**

# VILLAGE OF CUMBERLAND WATER SUPPLY

**Facility Location:**

2673 Dunsmuir Avenue  
Cumberland

**Facility Information:**

Facility Type: DWT

**Facility Sampling History:**

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Site #2 - 3328 Second Street, 3328 Second Street	27-Jan-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	27-Jan-2014	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	27-Jan-2014	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	27-Jan-2014	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	27-Jan-2014	L1	L1
Site #7 - 2476 Dunsmuir Avenue	27-Jan-2014	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	20-Jan-2014	L1.0	L1.0
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	13-Jan-2014	L1.0	L1.0
Site #5 - 3607 Small Road, 3607 Small Road	13-Jan-2014	L1.0	L1.0
Site #2 - 3328 Second Street, 3328 Second Street	6-Jan-2014	L1.0	L1.0
Site #7 - 2476 Dunsmuir Avenue	23-Dec-2013	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	16-Dec-2013	L1	L1
Site #1 - 2040 Derwent , 2040 Derwent	16-Dec-2013	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	16-Dec-2013	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	16-Dec-2013	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	16-Dec-2013	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	16-Dec-2013	L1	L1
Site #6 - 2563 Kendall Ave, 2563 Kendall Ave	16-Dec-2013	L1	L1
Site #7 - 2476 Dunsmuir Avenue	16-Dec-2013	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	12-Dec-2013	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	26-Nov-2013	L1.0	L1.0
Site #1 - 2040 Derwent , 2040 Derwent	26-Nov-2013	L1	L1
Site #2 - 3328 Second Street, 3328 Second Street	26-Nov-2013	L1	L1
Site #3 - 4700 Cumberland Road, 4700 Cumberland Road	26-Nov-2013	L1	L1
Site #4 - 3190 Royston Road, 3190 Royston Road	26-Nov-2013	L1	L1
Site #5 - 3607 Small Road, 3607 Small Road	26-Nov-2013	L1	L1



## VILLAGE OF CUMBERLAND WATER SUPPLY - Inspection Report

### Inspection Information:

Facility Type: DWT  
Inspection type: Routine  
Inspection date: November 18, 2014  
Follow-up Required: No

This facility was given a **low** hazard rating.

• More information on hazard ratings.

### Violations:

*A summary of the violations found during the inspection are listed below.*

#### Code Description / Observation / Corrective Action

#### 322 Emergency Response Plan

Observation: *(no observation)*

Corrective Action: *Reviewed and discussed decision tree for responding to a turbidity event in unfiltered drinking water. Incorporate response into Emergency Response Plan. See correspondence sent to operator Nov. 21, 2014 .*

#### 323 Other (Specify)

Observation: *Terms and Conditions*

Corrective Action: *Source protection risk analysis, including inventory of potential impacts has not been conducted in compliance with the completion date July 1, 2014. Agreed to complete before March 31, 2015. Reviewed upcoming completion date for develop, prioritize and implement mitigation strategies - completion date set as July 1, 2015.*

**Comments:** Met with Manager of Operations to review and discuss compliance dates pursuant to Terms and Conditions of Permit to Operate a Water Supply System.