



## **Village of Cumberland**

Japanese Canadian Cemetery Marker Conservation Project

REQUEST FOR PROPOSAL 2601

### **Addendum No. 1**

The following information is added to the Request for Proposals for this project:

#### **Questions and Answers**

**Q1** What is the water pressure of the water service?

**A1** Static pressure is 115 psi. The service line inside the meter box is  $\frac{3}{4}$ " , which has been reduced from a 2" water line to the meter box. A hose bib and shut-off has been scheduled to be installed by mid-March so the service may be used by the contractor.

**End of Addendum No.1**